

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8110-2117:0100 Page 1 of 1

CATEGORY: Decking For Wildland Urban Interface (W.U.I)

LISTEE: Timber Holdings USA, 451 S. River Road, Bedford, NH 03110
Contact: Brian Lotz (414) 750-2336
Email: brian@ironwoods.com


DESIGN: Iron Woods™ brand Ipe hardwood deck board 5 1/2" X 3/4". ^{minimum} Maximum 3/16" edge-to-edge plank spacing. Refer to the manufacturer's installation instructions and product data sheets.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name, Model number, rating and SFM label.

APPROVAL: Listed as solid wood decking materials for use in the Wildland Urban Interface areas.

DRAFT

Draft for Signature
Signature/Date: 

02-14-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: Listing Expires
Authorized By: **JAMES PARSEGIAN**, Program Coordinator
Fire Engineering Division